



# How-to Non-Res

Greenbuild: Phius Summit November 2025



# Getting Started

## Phius Certification Guidebook

- Section 0.5.3 Mixed-Use Projects
- Section 0.5.4 Non-Residential Projects
- Section 1.1 Process
  - 1.1.2 Phase 1: Paperwork
- Section 1.3 Co-requisite Requirements
  - Table 1.3.4.1.1 Non-Residential Base Source Energy Limits
  - Section 1.3.4.2 Electric Vehicle (EV) Charging Infrastructure
- Section 1.4 Design Guidance
  - 1.4.1.2 Multifamily, Mixed-Use and Non-Residential
- Section 1.4.4 Phius Energy Modeling Protocol for WUFI® Passive
  - 1.4.4.4 PH Case
  - 1.4.4.9 Non-Residential Interior Loads / Occupancy
  - 1.4.4.10 Ventilation / Rooms
- Section 1.5 On-Site Review

# Mixed-Use Projects

2024 Guidebook Section 0.5.3



# Mixed-Use Projects (Section 0.5.3)

Mixed-use projects come in two basic variants.

1. Usage types of all spaces are known at the time of design

**OR**

1. Part of the building is designed and finished for known usage types, and part of it is designed for an unknown future tenant who is responsible for completing construction in terms of plumbing, HVAC systems, interior finishes, insulation, etc. (aka “shell-lease”)



# Finished (“F”) vs Unfinished (“UF”)

## **Finished (“F”):**

Refers to spaces whose occupancy / tenant is known at the time of design.

## **Unfinished (“UF”):**

Refers to spaces intended for an unknown non-residential shell-lease.



# Phius' Mixed-Use Approach (Section 0.5.3.2)

## Phius encourages the entire building to be Certified, but...

- Partial Certification may be sought so long as >50% of the building floor area is included.
- If there are a mix of “F” and “UF” spaces planned and being certified, each must be separately metered and have its own mechanical systems. The predicted energy use can then be compared to actual usage.
  - For “UF” Spaces: If, between design certification and final certification, prospective tenants are found to occupy the UF space who are able and willing to meet the constraints of whole-building certification in their build-out plans, the tenant fit-out must be certified under its planned function rather than as an unfinished space.



# Four Paths (Section 0.5.3.2)

## Whole Building Certification

Separate energy models are created for residential and non-residential areas.  
100% of the iCFA.

- A. Combined
  - a. Overall source energy limit
  - b. Overall space conditioning targets
  - c. “UF” spaces may be Certified
- B. Separate
  - a. Individual source energy limit
  - b. Individual space conditioning targets
  - c. “UF” space may not be Certified

## Partial Building Certification

Separate energy models are created for residential and non-residential areas.  
>50% of the iCFA.

- C. Combined
  - a. Overall source energy limit
  - b. Overall space conditioning targets
  - c. “UF” spaces may be Certified
- D. Separate
  - a. Individual source energy limit
  - b. Individual space conditioning targets
  - c. “UF” space may not be Certified



# Table 0.5.3.2.0

Table 0.5.3.2.0 Mixed-Use Certification Matrix					
Mixed-Use Certification Paths		Whole Building Certification		Partial Building Certification	
		A	B	C	D
Modeling & Certification	Separate energy models for residential & non-residential.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
	100% of the building floor area is modeled / certified.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		
	≥ 50% of the building floor area must be modeled / certified.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
	Unknown non-residential spaces may not be certified alone.		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
	Follows UF Protocol outlined in Phius Mixed-Use Approach.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Source Energy Allowance	Determined for building by applying a mix of residential and non-residential allowances to certified spaces.	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
	Determined for building by applying a mix of residential and non-residential allowances to certified spaces.		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Space Conditioning Targets	Apply to the whole / certified portion of the building.	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
	Apply to partial building and must be met in each energy model.		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>

# Non-Residential Projects

2024 Guidebook Section 0.5.4



# Non-Residential Projects (Section 0.5.4)

## Things to keep in mind

- Space conditioning targets still apply
- Airtightness requirement still apply
- Source Energy limit is proportional to floor area
- More detailed information is required for:
  - a. Occupancy patterns
  - b. Plug loads
  - c. Lighting
  - d. Process loads
  - e. Ventilation patterns



# Dormitories & Hotels (Section 0.5.4.1)

Follow modeling protocol and on-site requirements based on whether the occupancy is assumed to be “Transient” or “Long-Term”.

Transient Occupancy:

- Occupant stays  $< 30$  days = Non-Residential

Long-Term Occupancy:

- Occupant stays  $\geq 30$  days = Residential

# Registering a Project

2024 Guidebook Section 1.1.2



# Registering a Project

- [Inquiry - Submit a Project Page](#)
  - Phase 1: Paperwork - [Request a Contract](#)



[Passive Building](#) ▾

[Certifications](#) ▾

[Standards](#) ▾

[Education](#) ▾

[Resources](#) ▾

## Submit a Project

Certification Support





# Providing Project Information

- Things to keep in mind
  - Registration quotes require information about each unique building or energy model.
  - Discrete use types and volumes require separate energy models.
  - Separate models or cases require individual line items in the



Description about each of the Certification paths can be found below.

[Phius Standards](#)

Project Information

Building Name	Quantity *	ICFA *	Number of Dwelling Units *
Residential	1	301559	331
Retail A	1	4946	0
Retail B	1	3826	0
Retail C/D	1	2508	0

Enter each unique building (or energy model) in the rows above. For non-residential buildings, input 0 for the number of dwelling units. For mixed-use, include each model and include the dwelling unit quantity for residential portions.

# Software & Performance Target Introduction



# WUFI & METr

- All Certification is done via modeling compliance
  - WUFI Passive
  - METr
- Monthly Modeling tool
- Single Zone
- Supports residential and non-residential buildings
- More flexibility on non-res cases



**METr**  
by phius



**WUFI® Passive**



# WUFI & METr

- Limitations:
  - Single Zone
  - Averaged annual internal gains
    - Not able to account for seasonal use
  - Simplified mechanical systems
    - Must calculate COPs externally
    - Cannot account for controls / BAS
  - **Not a load sizing tool**
    - Single Zone
    - Design Temps are not 99.6% & 0.4%
    - No latent load in peak cooling
      - Covered in crossover modeling
    - Loads are *ideal air loads*

## ANNUAL HEAT DEMAND



Transmission losses :	1,779,354	kBtu/yr
Ventilation losses:	1,216,175	kBtu/yr
Total heat losses:	2,995,529	kBtu/yr
Solar heat gains:	724,579	kBtu/yr
Internal heat gains:	2,649,458	kBtu/yr
Total heat gains:	3,374,036	kBtu/yr
Utilization factor:	59.9	%
Useful heat gains:	2,020,543	kBtu/yr

Annual heat demand:	974,986	kBtu/yr
Specific annual heat demand:	13,182.8	Btu/ft <sup>2</sup> /yr

## ANNUAL COOLING DEMAND

Solar heat gains:	852,212	kBtu/yr
Internal heat gains:	2,931,660	kBtu/yr
Total heat gains:	3,783,872	kBtu/yr
Transmission losses :	3,102,183	kBtu/yr
Ventilation losses:	1,652,330	kBtu/yr
Total heat losses:	4,754,514	kBtu/yr
Utilization factor:	57.6	%
Useful heat losses:	2,739,798	kBtu/yr

Cooling demand - sensible:	1,044,074	kBtu/yr
Cooling demand - latent:	12,714	kBtu/yr
Annual cooling demand:	1,056,788	kBtu/yr
Specific annual cooling demand:	14.3	kBtu/ft <sup>2</sup> /yr





# Target Calculation

Visualized components

Nr	Name	Type	Attachment outside	Area [ft²]	Orientation	Inclination [°]	R [hr ft² °F/Btu]
1	Roof	Opaque	Outer air	73813.22	Horizontal (100 %)	0	30.182
2	Slab	Opaque	Ground	73957.22	Horizontal (100 %)	180	5.007
3	Cafeteria Skylight	Transparent	Outer air	144	Horizontal (100 %)	0	1.9
4	Exterior Windows	Transparent	Outer air	9462.66	S (37 %), E (13 %), W (13 %)	90	2.523
5	Exterior Walls	Opaque	Outer air	17050.7	S (37 %), E (13 %), W (13 %)	90	14.918
6	Exterior Door	Opaque	Outer air	524.99	S (44 %), E (12 %), W (4 %)	90	2.702

Total area of envelope components (interior components excluded) 174952.79

Project information

Name	Zone1
Type	Simulated zone
PH case	Passive house: School

Geometry / Specific heat capacity

Setting	Setting way	Value
Visualized volume [ft³]	From visualized geometry	970556.51
Gross volume [ft³]	From visualized volume and components	970556.51
Net volume [ft³]	Estimated from gross volume	73966.05
Interior conditioned floor area [ft²]	User defined	73966.05
Specific heat capacity [Btu/ft²F]	Lightweight	11

Additional data

Humidity capacity [lb/(lbw/lbda) ft²]	143.3713
---------------------------------------	----------

### Phius 2024

New Construction\*  
Performance Criteria Calculator v24.1

**UNITS:** IMPERIAL (IP) ▾

**BUILDING FUNCTION:** NON-RESIDENTIAL ▾

**STATE / PROVINCE:** ILLINOIS ▾

**CITY:** CHICAGO MIDWAY AP ▾

**ASHRAE 169 Climate Zone:** 5A

---

**Envelope Area (ft²):** 174,952.8

**ICFA (ft²):** 73,966.1

**Average Occupancy:** 300

**Design (Max) Occupancy:** 1,478

---

**Space Conditioning Criteria**

Annual Heating Demand	9.6	kBtu/ft²·yr
Annual Cooling Demand	6.5	kBtu/ft²·yr
Peak Heating Load	8.3	Btu/ft²·hr
Peak Cooling Load	4.0	Btu/ft²·hr

---

**Source Energy Criteria**

Phius CORE	30.0	kBtu/ft²·yr
Phius ZERO	0	kBtu/ft²·yr

\*Retrofit projects that qualify for the Phius REVIVE 2024 standard should refer to the Phius Certification Guidebook v24.1 for guidance and requirements.



# Target Calculation

Utilization pattern   Occupancy   Office equipment   Kitchen equipment   Lighting   Process

Occupant quantity [-] **300**

Humidity sources [lb/(ft<sup>2</sup>hr)] 0.00041

Name	Utilization pattern	Activity of persons	Occupant quantity	Floor area of utilization zone [ft <sup>2</sup> ]
Occupants	Pattern 1: School	Adult, standing or light work	<b>1478</b>	

Additional data

Heat loss due to evaporation (per person) [Btu/	51.1821
Heat loss due to flushing toilets (cold water)	<input checked="" type="checkbox"/>
Number of flush toilets [-]	1
Toilet utilization pattern	Pattern 1: School
Use default values for school	<input checked="" type="checkbox"/>

Hint: Input of occupant quantity and floor area of utilization zone is alternative. Only one of them should be defined.

**No Impact on Targets**

### Phius 2024

New Construction\*  
Performance Criteria Calculator v24.1

UNITS: IMPERIAL (IP) ▾

BUILDING FUNCTION: **NON-RESIDENTIAL** ▾

STATE / PROVINCE: ILLINOIS ▾

CITY: CHICAGO MIDWAY AP ▾

ASHRAE 169 Climate Zone: 5A

---

Envelope Area (ft<sup>2</sup>) 174,952.8

ICFA (ft<sup>2</sup>) 73,966.1

Average Occupancy **300**

Design (Max) Occupancy **1,478**

---

#### Space Conditioning Criteria

Annual Heating Demand	9.6	kBtu/ft <sup>2</sup> yr
Annual Cooling Demand	6.5	kBtu/ft <sup>2</sup> yr
Peak Heating Load	8.3	Btu/ft <sup>2</sup> hr
Peak Cooling Load	4.0	Btu/ft <sup>2</sup> hr

---

#### Source Energy Criteria

Phius CORE	30.0	kBtu/ft <sup>2</sup> yr
Phius ZERO	0	kBtu/ft <sup>2</sup> yr

\*Retrofit projects that qualify for the Phius REVIVE 2024 standard should refer to the Phius Certification Guidebook v24.1 for guidance and requirements.



# Envelope Area

## Different Boundary Conditions:

- Space with same inner conditions
  - Attached, conditioned, non-certified space
  - Small load from infiltration
  - **Does count towards envelope area**
- Zone 1:
  - Attached, conditioned, certified space
  - No loads
  - **Does NOT count towards envelope area**

The screenshot shows the WUFI software interface. The project tree on the left lists components for 'Case 1: ASHRAE 90.1 - 2019', including 'Roof', 'Slab', 'Cafeteria', and 'Exterior V'. The main window displays the 'Roof' component details.

Type/Attachment	
Type	Opaque
Inner side	Zone 1: Zone1
Outer side	Space with the same inner conditions

Data	
Area [m <sup>2</sup> ]	Zone 1: Zone1
Inclination [°]	Outer air
	Ground
Orientation	Space with the same inner conditions
Perimeter [m]	Horizontal (100 %)
	275.59

Parameters	
Rsi [hr ft <sup>2</sup> °F/Btu]	0.5678
Rse [hr ft <sup>2</sup> °F/Btu]	0.2271
Thermal resistance (homogenous) [hr ft <sup>2</sup> °F/Btu]	30.182
U [Btu/hr ft <sup>2</sup> °F]	0.0323

PHIUS + Certification:  
Components assigned to 'Space with the same inner conditions':  
Zone X: Interzonal heat/moisture transfer  
Outer air: Ambient climate (air, radiation)  
Ground: Overall combined ground conditions  
Space with...: Adiabatic (no heat/moisture transfer)



# Custom Targets

## Contact Us!

- Buildings that may require custom targets:
  - High ventilation loads
    - > 1.0 ACH
  - High Internal Gains
    - Hospitals
    - Laboratories
    - Food processing
    - Oyster hatchery
    - Factory
    - etc

The screenshot shows the Phius contact form interface. At the top is the Phius logo. Below it is the heading "Contact Phius". The form contains the following text:

**Office: (312) 561-4588**  
*\*Note, this number goes to our main office voicemail system. For quicker response please submit your question using the form below.*

**Mailing Address:**  
53 W. Jackson Blvd., Suite 1432  
Chicago, IL 60604

**Before submitting a ticket, please review the following links, which may help resolve your issues.**

- Register for an Upcoming Training and view the training schedule [here](#).
- Reschedule your existing Phius CPHC, CPHB, Rater, Verifier Training or Exam [here](#).
- Self-Report Phius CEUs [here](#).
- Log in to the [Phius Website](#) or [Phius Portal](#) to access your Phius Alliance discounts for training and other events.
- Log in to the [Phius Training Site](#) for professional and continuing education training.

Did this resolve your issue? \*

-Select-

Next



1/3



# Custom Targets

## Process

- Follows target setting process
  - Use optimization to determine ideal envelope package for internal conditions
  - Crossover modeling in WUFI
  - WUFI space conditioning results become targets
- Needs:
  - Geometry
  - Internal gains
  - Occupancy schedule



# Non-Residential Source Energy Limits

2024 Guidebook Table 1.3.4.1.1



# Non-Residential Source Energy Limits

- Improved source energy target for climate sensitivity and non-residential loads
  - Previous target was 24.5 kBtu/sf yr for all buildings
- Utilized ASHRAE 100 data
  - Reduced existing building usage by Phius median source energy savings
  - “Allowance” for humid climates for dehumidification

Source Energy Threshold - Non-Residential





# Non-Residential Source Energy Limits

(Table 1.3.4.1.1)

- Limit varies by climate zone
- Process load source energy allowances are added on to this 'base' limit
- There is no target for Unfinished Spaces

Table 1.3.4.1.1 Non-Residential Base Source Energy Limits

ASHRAE 169 Climate Zone	Source Energy Limit [kBtu/ft <sup>2</sup> .yr]
1A	31.0
1B	28.0
2A	28.0
2B	25.0
3A	27.0
3B	23.0
3C	22.0
4A	28.0
4B	23.0
4C	21.0
5A	30.0
5B	25.0
5C	23.0
6A	34.0
6B	30.0
7	39.0
8	46.0

# Non-Res Modeling: Setting up → PH Case

2024 Guidebook Section 1.4.4.4



# Typ. Non-Res Modeling Protocol

1. PH Case > Set 'Building category' to Non-residential  
> Set 'Occupancy type'

Use for all

non-res projects that have a defined program that do not fall under the category of school

> Office/Adminin:

> School: Use for

> Other: Never

schools

use

General	Additional data	Foundation interface	Manual J
<b>Parameters</b>			
Building category	Non-residential		
Occupancy type	Office/Administrative building		
Building status	Office/Administrative building		
Type	School Other		
Indoor temperature [°F]	68		
Internal gains setting	Calculated		
Internal heat gains [Btu/hr ft²]			
Occupancy setting method	Design		
Number of occupants			
Number of units [-]	1		
Number of floors	1		

WUFI

General	Additional data	Source energy/CO2-factor
<b>Parameters</b>		
Building category	Non-residential	
Occupancy type	Office/Administrative building	
Building status	Office/Administrative building	
Type	School Other	
Indoor temperature [°F]	Other	
Internal gains setting	Calculated	
Internal heat gains [Btu/hr ft²]		
Occupancy setting method	Design	
Number of occupants		
Number of units [-]	1	
Number of floors	1	

METR



# Unfinished (“UF”) Modeling Protocol

## **Finished (“F”):**

Refers to spaces whose occupancy / tenant is known at the time of design.

## **Unfinished (“UF”):**

Refers to spaces intended for an unknown non-residential shell-lease.

## **1.4.4.9 Non-Residential Internal Loads / Occupancy**

### Unfinished (UF) Spaces:

It is necessary to assume a scenario to apply the certification criteria in regards to calculating the heating and cooling loads and demands of Unfinished spaces (UF). For the source energy criterion, there is no additional source energy allowance for unfinished spaces and therefore no assumption about their energy use.



# Unfinished (“UF”) Modeling Protocol

1. Case 1 > Set ‘Certificate criteria’ to PHIUS+ 2018’

General Report data & results

Name

Remarks

Calculation

Certificate criteria **PHIUS+ 2018** ▼

- Default Standard
- PHIUS+ 2015
- PHIUS+ 2018**
- Italian
- PHIUS+ 2018 Core
- PHIUS+ 2018 Source Zero
- Phius CORE 2021
- Phius ZERO 2021

2. PH Case > Set ‘Building category’ to Non-residential

> Set ‘Occupancy type’ to Undefined/unfinished\*

Parameters	
Building category	Non-residential
Occupancy type	Undefined/unfinished
Building status	In planning
Type	New construction
Indoor temperature [°F]	68
Internal gains setting	Calculated
<b>Internal heat gains [Btu/hr ft²]</b>	<b>1</b>
Occupancy setting method	Design
Number of occupants	35
Number of units [-]	1
Number of floors	1

\*This option will ONLY be available when the ‘Certificate criteria’ is correctly set in Step 1.

(Not currently available in METr)



# Non-Res DHW Usage

- Hot water tap-openings per person per day
  - Assumes *every* occupant opens *every* tap in the building this number of times
- Hot water tap opening utilization days per year
  - Number of days the building is open per year
- DHW consumption (140F) per person per day
  - Default: 3.2 gal

Additional parameters	
Preferred minimum indoor temperature for night ventilation [°F]	68
Overheating temperature threshold [°F]	77
Fresh air per person [cfm]	18
Hot water tap-openings per person per day [-]	3
Hot water tap-opening utilization days per year [days/yr]	365
Air-tightness metric	Envelope airtightness at 50 Pa
Envelope airtightness at 50 Pa [cfm/ft²]	
Non combustible materials	<input type="checkbox"/>
Type of ventilation system	Balanced PH ventilation
Max. humidity ratio (if dehumidification) [lbwt/lba]	0.012
Building wind exposure	Several sides exposed - moderate screening
Wind screening coefficient (e) [-]	0.07
Wind exposure factor (f) [-]	15
Wind shield factor [-]	0.05
Optional data (if not defined default value will be calculated)	
DHW consumption (140°F) per person per day [gal/Person/day]	3.2
Average cold water temperature of the supply [°F]	
Mechanical room temperature [°F]	68

WUFI

Additional parameters	
Preferred minimum indoor temperature for night ventilation [°C]	20
Overheating temperature threshold [°C]	25
Fresh air per person [m³/h]	30.58
Hot water tapp-opening per person per day [-]	3
Hot water tapp-opening utilization days per year [days/a]	365
Air-tightness metric	Envelope airtightness at 50 Pa
Envelope airtightness at 50 Pa [m³/m²h]	
Non combustible materials	<input type="checkbox"/>
Type of ventilation system	Balanced PH ventilation
Max. humidity ratio (if dehumidification) [g/kg]	12
Building wind exposure	Several sides exposed - moderate screening
Wind screening coefficient (e) [-]	0.07
Wind exposure factor (f) [-]	15
Wind shield factor [-]	0.05
DHW consumption (60°) per person per day [Ltr/Person/day]	3.2
Average cold water temperature of the supply [°C]	
Mechanical room temperature [°C]	

MET+





# Non-Res DHW Usage Inputs for WUFI

v25.0 - 2025.05

Phius Non-Residential Effective DHW Usage Calculator				Required inputs	Results
Type of Occupant	# ppl	gal/person/day (@110F)	gal/day	Notes	Instructions
Students	200	3.2	640	DHW at 110F (60 F delta from 50F)	Input high-level occupancy groups & quantities of people within that group. Then, input estimated gal/person/day (@110F, typ). Use 3.2 gallons as a default if unknown.
Teachers	20	3.2	64		
Office/Admin	10	3.2	32		
			0		
			0		
			0		
Summed Total			736		
Calculated Total			491	DHW at 140F (90 F delta from 50F)	-
Kitchen Staff/Janitors	10	3.2	32	DHW at 140F (90 F delta from 50F)	Input any occupants that may use 3.2 gallons/day of 140F water
Total	240		523	DHW at 140F (90 F delta from 50F)	-
			2.2	effective gal/p.day for WP model (at 140F)	Enter the calculated value to the left in WUFI Passive under: PH Case > Additional Data > <b>DHW Consumption (140F) per person per day</b>

Total DHW taps in the building					
30					
Type of Occupant	# ppl	# HW taps opened/person/day	WUFI - Tap openings/person.day	Notes	Instructions
Students	200	3	0.083	averages per occupancy group	First, input the total number of DHW taps in the building in cell B19. Then, input the total estimated # of taps opened by each occupant on a daily basis. Use 3 taps (or less, if <3 total taps) as a default if unknown.
Teachers	20	3	0.008		
Office/Admin	10	3	0.004		
	0		0.000		
	0		0.000		
Kitchen Staff/Janitors	10	3	0.004		
Total	240		0.10	effective hot water-tap openings/p.day for WP model	Enter the calculated value to the left in WUFI Passive under: PH Case > Additional Data > <b>Hot water tap-openings per person per day</b>

General	Additional data	Foundation interface	Manual J
<b>Additional parameters</b>			
<b>Required data</b>			
Preferred minimum indoor temperature for night ventilation [°F]	68		
Overheating temperature threshold [°F]	77		
Fresh air per person [cfm]	18		
Hot water tap-openings per person per day [-]	0.10		
Hot water tap-opening utilization days per year [days/yr]	365		
Air-tightness metric	Envelope airtightness at 50 Pa		
Envelope airtightness at 50 Pa [cfm/ft²]	0.06		
Non combustible materials	<input type="checkbox"/>		
Type of ventilation system	Balanced PH ventilation		
Max. humidity ratio (if dehumidification) [lbw/lba]	0.012		
Building wind exposure	Several sides exposed - moderate screening		
Wind screening coefficient (e) [-]	0.07		
Wind exposure factor (f) [-]	15		
Wind shield factor [-]	0.05		
<b>Optional data (if not defined default value will be calculated)</b>			
DHW consumption (140°F) per person per day [gal/Person/day]	2.2		
Average cold water temperature of the supply [°F]	50		
Mechanical room temperature [°F]	40		

# Non-Res Modeling: Internal Loads / Occupancy

2024 Guidebook Section 1.4.4.9



# Non-Res Utilization Patterns

- Used for
  - Lighting energy calculation
  - Internal gains
- Columns highlighted in red (left) should be customized to align with the project-specific utilization schedule(s)
  - Provide a narrative supporting the modeled patterns for Certification

**N-8 Non-Residential Utilization Patterns**

Standard Default Patterns (per DIN V 18599-10:2007-02, Table 4) for Internal Loads and Occupancy Calculations for Non-Residential Buildings

Table N-8.0 Non-Residential Utilization Patterns									
Building Type	Space Type	Notes	Start [time]	End [time]	Annual Utilization Days [d/a]	Maintained Illuminance [lux]	Height of the working plane [ft]	Relative Absence	Factor of lighting relative to building's operation time
Library	magazine and stores	-	8	20	300	100	2.6	0.9	1
	open stacks areas	-	8	20	300	200	2.6	0	1
	reading rooms	-	8	20	300	500	2.6	0	1
Office	1 - 6 workstations	-	7	18	250	500	2.6	0.3	0.7
	7+ workstations	-	7	18	250	500	2.6	0	1
	Meeting, conference, and seminar room	-	7	18	250	500	2.6	0.5	1
Restaurant	Dining Area	-	10	24	300	200	2.6	0	1
	Kitchen	-	10	23	300	500	2.6	0	1
	Kitchen	preparation room or storeroom	7	23	300	300	2.6	0.5	1
School	Cafeteria	Canteen	8	15	250	200	2.6	0	1
	Classroom	school and nursery school	8	15	200	300	2.6	0.25	0.9
	Lecture Room, Auditorium	-	8	18	150	500	2.6	0.25	0.7



# Non-Res Utilization Patterns

- Columns highlighted in red (middle) influence lighting, but are overridden by modeling protocol in the 'Lighting' section.
  - Lux inputs can be used when installed lighting power is unknown, in the design or feasibility study stage of the project
  - Actual lighting power density should be modeled for certification

## N-8 Non-Residential Utilization Patterns

Standard Default Patterns (per DIN V 18599-10:2007-02, Table 4) for Internal Loads and Occupancy Calculations for Non-Residential Buildings

Building Type	Space Type	Notes	Start [time]	End [time]	Annual Utilization Days [d/a]	Maintained Illuminance [lux]	Height of the working plane [ft]	Relative Absence	Factor of lighting relative to building's operation time
Library	magazine and stores	-	8	20	300	100	2.6	0.9	1
	open stacks areas	-	8	20	300	200	2.6	0	1
	reading rooms	-	8	20	300	500	2.6	0	1
Office	1 - 6 workstations	-	7	18	250	500	2.6	0.3	0.7
	7+ workstations	-	7	18	250	500	2.6	0	1
	Meeting, conference, and seminar room	-	7	18	250	500	2.6	0.5	1
Restaurant	Dining Area	-	10	24	300	200	2.6	0	1
	Kitchen	-	10	23	300	500	2.6	0	1
	Kitchen	preparation room or storeroom	7	23	300	300	2.6	0.5	1
School	Cafeteria	Canteen	8	15	250	200	2.6	0	1
	Classroom	school and nursery school	8	15	200	300	2.6	0.25	0.9
	Lecture Room, Auditorium	-	8	18	150	500	2.6	0.25	0.7



# Non-Res Utilization Patterns

- Default values in the columns highlighted in red (right) should be left as-is according to Guidebook (2024) Appendix N-8

## N-8 Non-Residential Utilization Patterns

Standard Default Patterns (per DIN V 18599-10:2007-02, Table 4) for Internal Loads and Occupancy Calculations for Non-Residential Buildings

Building Type	Space Type	Notes	Start [time]	End [time]	Annual Utilization Days [d/a]	Maintained Illuminance [lux]	Height of the working plane [ft]	Relative Absence	Factor of lighting relative to building's operation time
Library	magazine and stores	-	8	20	300	100	2.6	0.9	1
	open stacks areas	-	8	20	300	200	2.6	0	1
	reading rooms	-	8	20	300	500	2.6	0	1
Office	1 - 6 workstations	-	7	18	250	500	2.6	0.3	0.7
	7+ workstations	-	7	18	250	500	2.6	0	1
	Meeting, conference, and seminar room	-	7	18	250	500	2.6	0.5	1
Restaurant	Dining Area	-	10	24	300	200	2.6	0	1
	Kitchen	-	10	23	300	500	2.6	0	1
	Kitchen	preparation room or storeroom	7	23	300	300	2.6	0.5	1
School	Cafeteria	Canteen	8	15	250	200	2.6	0	1
	Classroom	school and nursery school	8	15	200	300	2.6	0.25	0.9
	Lecture Room, Auditorium	-	8	18	150	500	2.6	0.25	0.7



# Non-Res Utilization Patterns & Occupancy

- **Simplicity is key**
  - Unique utilization patterns are only needed when major space types within the building are used differently by different groups of occupants
- **Start with the Phius Non-res Occupancy calculator**
  1. Define utilization patterns for major space types only (App. N-8)
  2. Define how occupants will typically use each space

Calculating Occupancy for Non-Residential Phius projects					
Occupant Quantity	70	For input in WUFI the Occupancy > Occupant Quantity			
Maximum Occupancy	237	For input in the Phius 2021 target setting calculator			

1. Utilization Patterns for WUFI & Occupancy Inputs					
Name	Begin Utilization	End Utilization	Annual Utilization Days	Relative Absence	Occupant Quantity for Pattern
Classroom (School)	7.0	16.0	240	0.25	215.0
Workgroup Office	7.0	17.0	240	0.30	10.0
Janitorial	5.0	22.0	300	0.90	2.0
Food Prep	7.0	16.0	240	0.25	10.0
	0.0	0.0		0.00	0.0
	0.0	0.0		0.00	0.0
	0.0	0.0		0.00	0.0
	0.0	0.0		0.00	0.0

2.						Use 24 Hour Time (1:00 pm = 13)							Maximum Occupancy per day						
Spaces	Pattern	Start Hours	End Hours	Weeks/yr	Relative Absence	M	T	W	TH	F	Sa	Su	M	T	W	TH	F	Sa	Su
Students in Class	Classroom (School)	7	16	50	0.25	200	200	200	200	200	0	0	200	200	200	200	200	0	0
Teachers in Class	Classroom (School)	7	16	50	0.25	15	15	15	15	15	0	0	15	15	15	15	15	0	0
Office/Admin	Workgroup Office	7	17	50	0.3	10	10	10	10	10	0	0	10	10	10	10	10	0	0
Janitors	Janitorial	5	22	50	0.9	2	2	2	2	2	2	2	2	2	2	2	2	2	2
Kitchen Staff	Food Prep	7	16	50	0.25	10	10	10	10	10	0	0	10	10	10	10	10	0	0



# Non-Res Utilization Patterns

## Calculating Occupancy for Non-Residential Phius projects

Occupant Quantity	70	For input in WUFI the Occupancy > Occupant Quantity
Maximum Occupancy	237	For input in the Phius 2024 target setting calculator

## Utilization Patterns for WUFI & Occupancy Inputs

Name	Begin Utilization	End Utilization	Annual Utilization Days	Relative Absence	Occupant Quantity for Pattern
Classroom (School)	7.0	16.0	240	0.25	215.0
Workgroup Office	7.0	17.0	240	0.30	10.0
Janitorial	5.0	22.0	300	0.90	2.0
Food Prep	7.0	16.0	240	0.25	10.0
	0.0	0.0		0.00	0.0
	0.0	0.0		0.00	0.0
	0.0	0.0		0.00	0.0
	0.0	0.0		0.00	0.0

Use 24 Hour Time (1:00 pm = 13)

Maximum Occupancy per day

Spaces	Pattern	Start Hours	End Hours	Weeks/yr	Relative Absence	M	T	W	TH	F	Sa	Su
Students in Class	Classroom (School)	7	16	50	0.25	200	200	200	200	200	0	0
Teachers in Class	Classroom (School)	7	16	50	0.25	15	15	15	15	15	0	0
Office/Admin	Workgroup Office	7	17	50	0.3	10	10	10	10	10	0	0
Janitors	Janitorial	5	22	50	0.9	2	2	2	2	2	2	2
Kitchen Staff	Food Prep	7	16	50	0.25	10	10	10	10	10	0	0



# Non-Res Utilization Patterns

WUFI Navigation:

Internal Loads/Occupancy > Utilization Pattern

METr Navigation:

Shared Objects > Utilization patterns > Internal Loads

Name	Begin utilization [hr]	End utilization [hr]	Annual utilization days [days/yr]	Illumination level [lux]	Height of utilization level	Relative absence [-]	Part use factor of operating period for lighting [-]
Classroom (School)	7	16	240	500	Level 2: 2.62 ft	0.25	1
Workgroup Office	7	17	240	500	Level 2: 2.62 ft	0.3	1
Janitorial	5	22	300	500	Level 1: 0 ft	0.9	1
Food Prep	7	16	240	500	Level 2: 2.62 ft	0.25	1

**From calculator or N-8** **App N-8**

Nr	Name	Begin utilization [hrs]	End utilization [hrs]	Annual utilization days [days/yr]	Illumination level [lux]	Height of utilization level	Relative absence [-]	Part use factor of oper. period for lighting [-]
1	Classroom (School)	7	16	240	500	Level 2: 0.8 m	0.25	1
2	Workgroup Office	7	17	240	500	Level 2: 0.8 m	0.3	1
3	Janitorial	5	22	300	500	Level 2: 0.8 m	0.9	1
4	Food Prep	7	16	240	500	Level 2: 0.8 m	0.25	1

Optional data: Work Space

Average occupancy [ft <sup>2</sup> /Person]	
Room setpoint temperature [°F]	
Heating reduction temperature [°F]	
Daily utilization hours [hrs/d]	
Annual utilization hours [hrs/yr]	
Annual utilization hours during daytime [hrs/yr]	
Annual utilization hours during nighttime [hrs/yr]	
Daily heating operation hours [hrs/d]	
Daily ventilation operation hours [hrs/d]	
Number of max water tap openings per day [-]	

**ALWAYS Leave BLANK**


Optional data

Average occupancy [m <sup>2</sup> /Person]	
Room setpoint temperature [°C]	
Heating reduction temperature [K]	
Daily utilization hours [hrs/d]	
Annual utilization hours [hrs/a]	
Annual utilization hours during daytime [hrs/a]	
Annual utilization hours during nighttime [hrs/a]	
Daily heating operation hours [hrs/d]	
Daily ventilation operation hours [hrs/d]	
Number of max water tabs per day [-]	




# School Utilization Patterns

- Typical school with multiple occupancy groups & space types
  - Several patterns are appropriate
    - Janitorial staff may be in the building long after students leave.
    - Kitchen staff may not be there for the full day.
    - Are there any after school programs?
    - Etc...



## WUFI

Utilization pattern	Occupancy	Office equipment	Kitchen equipment	Lighting	Process loads				
Name	Begin utilization [hr]	End utilization [hr]	Annual utilization days [days/yr]	Illumination level [lux]	Height of utilization level	Relative absence [-]	Part use factor of operating period for lighting [-]		
Classroom (School)	7	16	240	500	Level 2: 2.62 ft	0.25	1	New	
Workgroup Office	7	17	240	500	Level 2: 2.62 ft	0.3	1	Delete	
Janitorial	5	22	300	500	Level 1: 0 ft	0.9	1	Copy	
Food Prep	7	16	240	500	Level 2: 2.62 ft	0.25	1	Insert	




## METr

Building elements: Utilization patterns									
Room ventilation: Internal loads									
Utilization patterns - loads									
Nr	Name	Begin utilization [hrs]	End utilization [hrs]	Annual utilization days [days/yr]	Illumination level [lux]	Height of utilization level	Relative absence [-]	Part use factor of oper. period for lighting [-]	
1	Classroom (School)	7	16	240	500	Level 2: 0.8 m	0.25	1	
2	Workgroup Office	7	17	240	500	Level 2: 0.8 m	0.3	1	
3	Janitorial	5	22	300	500	Level 2: 0.8 m	0.9	1	
4	Food Prep	7	16	240	500	Level 2: 0.8 m	0.25	1	




# Office Utilization Patterns

- Typical office with single-shift operation
  - One pattern is enough to represent the entire building & all spaces within it
    - Office workstations
    - Kitchen
    - Bathrooms
    - Etc...



WUFI

Name	Begin utilization [hr]	End utilization [hr]	Annual utilization days [days/yr]	Illumination level [lux]	Height of utilization level	Relative absence [-]	Part use factor of oper. period for lighting [-]
Work Space	7	18	250	500	Level 2: 2.62 ft	0.3	1



METr

Nr	Name	Begin utilization [hrs]	End utilization [hrs]	Annual utilization days [days/a]	Illumination level [lux]	Height of utilization level	Relative absence [-]	Part use factor of oper. period for lighting [-]
1	Work Spaces	7	18	250	500	Level 2: 0.8 m	0.3	1



# Unfinished (“UF”) Utilization Pattern

- Beginning utilization
  - Enter 0
- End utilization
  - Enter 24
- Annual utilization days
  - Enter 365
- Illumination level
  - Enter 300
- Height of utilization
  - Enter 2.62
- Relative absence
  - Enter 1
- Part use factor of building period for lighting
  - Enter 1
- Optional Data
  - Leave BLANK. No inputs needed

Utilization pattern								Occupancy	Office equipment	Kitchen equipment	Lighting	Process loads
Name	Begin utilization [hr]	End utilization [hr]	Annual utilization days [days/yr]	Illumination level [lux]	Height of utilization level	Relative absence [-]	Part use factor of operating period for lighting [-]					
UF Utilization Pattern	0	24	365	300	Level 2: 2.62 ft	1	1					

New

Delete

Copy

Insert

New/Insert

after

Optional data: Work Space	
Average occupancy [ft <sup>2</sup> /Person]	
Room setpoint temperature [°F]	
Heating reduction temperature [°F]	
Daily utilization hours [hrs/d]	
Annual utilization hours [hrs/yr]	
Annual utilization hours during daytime [hrs/yr]	
Annual utilization hours during nighttime [hrs/yr]	
Daily heating operation hours [hrs/d]	
Daily ventilation operation hours [hrs/d]	
Number of max water tap openings per day [-]	



# Non-Res Occupancy

- WUFI/METr Navigation:
  - Zone 1 > Internal Loads
- Occupant Quantity (whole-building average)
  - Average # of occupants in all spaces 24/7/365
  - Calculated in the 'Non-res occupancy calculator'
- Impacts DHW usage & supply air ventilation

Calculating Occupancy for Non-Residential Phius projects		
Occupant Quantity	46	For input in WUFI the Occupancy > Occupant Quantity
Maximum Occupancy	227	For input in the Phius 2021/2024 target setting calculator

## WUFI

Utilization pattern	Occupancy	Office equipment	Kitchen equipment	Lighting	Process loads
Occupant quantity [-]	46				
Humidity sources [lb/(ft <sup>2</sup> hr)]	0.00041				

## METr

Occupancy	Office equipment	Kitchen equipment	Lighting	Process loads
Occupant quantity [-]	46			
Humidity sources [lb/(ft <sup>2</sup> hr)]	0.00041			



# Non-Res Occupancy

- Occupancy Groups (design max. per space)
  - In general, there should be one occupancy group per unique utilization pattern
  - Calculated in the 'Non-res occupancy calculator'
  - Don't** include:
    - Transient spaces such as stairwells/circulation
    - Restrooms
    - Auxiliary spaces serving the 'main' occupied areas (i.e. conference rooms serving a broader office environment)

		Use 24 Hour Time (1:00 pm = 13)				Maximum Occupancy per day						
Spaces	Pattern	Start Hours	End Hours	Weeks/yr	Relative Absence	M	T	W	TH	F	Sa	Su
Students in Class	Classroom (School)	7	16	50	0.25	200	200	200	200	200	0	0
Teachers in Class	Classroom (School)	7	16	50	0.25	15	15	15	15	15	0	0
Office/Admin	Workgroup Office	7	17	50	0.3	10	10	10	10	10	0	0
Janitors	Janitorial	5	22	50	0.9	2	2	2	2	2	2	2
Kitchen Staff	Food Prep	7	16	50	0.25	10	10	10	10	10	0	0

WUFI

Name	Utilization pattern	Activity of persons	Occupant quantity	Floor area of utilization zone [R²]	
Students in Class	Pattern 1: Classroom	Adult, standing or light work	200		<input type="button" value="New"/> <input type="button" value="Delete"/> <input type="button" value="Copy"/> <input type="button" value="Insert"/> <input type="button" value="New/Insert after"/>
Teachers in Class	Pattern 1: Classroom	Kid, 0 - 10 years	15		
Office/Admin Staff	Pattern 2: Workgroup O	Adult, sitting	10		
Janitorial	Pattern 3: Janitorial	Adult, standing or light work	2		
Kitchen Staff	Pattern 4: Food Prep	Adult, standing or light work	10		

METr

Nr	Name	Utilization pattern	Activity of persons	Occupant quantity	Floor area of utilization zone [R²]
1	Students in Class	Pattern 1: Classroom	Kid, 0 - 10 years	200	
2	Teachers in Class	Pattern 1: Classroom	Adult, standing or light work	15	
3	Office/Admin Staff	Pattern 2: Workgroup Office	Adult, sitting	10	
4	Janitorial	Pattern 3: Janitorial	Adult, standing or light work	2	



# Unfinished (“UF”) Occupancy

- Occupant quantity (whole-building average)
  - Assume 30% of the design (maximum) occupancy for the building
- Occupancy groups (design max. per space)
  - Add one line item
  - Complete inputs in WUFI to represent the maximum occupancy for the most realistic commercial tenant for the space according to IBC 2021 Table 1004.5 (or local code if more stringent)

**Example:** A project under development has 3,000 ft<sup>2</sup> of additional commercial space available for lease. The owner hopes to lease it to a small local business for office space.

- Design (maximum)
  - IBC 2021: 150 GSF/person
  - $3,000 / 150 = 20$  occupants
- Average occupancy (for target setting)
  - $20 * 0.3 = 6$  occupants



# Non-Res Occupancy - Additional Data

- Heat loss due to evaporation
  - Leave as-is, default 51.2 BTU/hr
- Heat loss due to flushing toilets
  - Leave as-is, box checked is default
- **Number of flush toilets**
  - Enter quantity of flush toilets planned in the project
- **Toilet utilization pattern**
  - Select utilization pattern with the most 'Annual utilization days'
- **Use default values for school?**
  - Check this box only when modeling a school

## WUFI

Additional data	
Heat loss due to evaporation (per person) [Btu/	51.1821
Heat loss due to flushing toilets (cold water)	<input checked="" type="checkbox"/>
Number of flush toilets [-]	49
Toilet utilization pattern	Pattern 1: Classroom
Use default values for school	<input checked="" type="checkbox"/>

## METr

Additional data	
Heat loss due to evaporation (per person) [Btu/hr]	51.1821
Heat loss due to flushing WC (coldwater)	<input checked="" type="checkbox"/>
Number of flush toilets [-]	49
Toilet utilization pattern	Pattern 1: Classroom
Use default values for school	<input checked="" type="checkbox"/>



# Utilization & Occupancy - Supporting Documentation

- Provide a narrative describing:
  - Operating periods of spaces within the model
    - Daily start/End time
    - Weekly utilization days (M-F, S/S)
    - Annual utilization weeks/yr
  - Occupancy groups using the space(s)
    - Full-time employees (FTE's)
    - Part-time employees
    - Age groups (schools, teachers vs students, etc)
    - Visitors / patients / customers
    - etc...
  - Quantity of people within each occupancy group



# Non-Res Office Equipment

## • Simple Method

- Create one line-item in WUFI with type set to **'User defined'**
- Calculate/estimate annual kWh/yr of all planned equipment (except kitchen equipment)
  - $\text{kWh/yr} = \text{EPD} * \text{iCFA} * \text{EFLH} / 1000$
  - $\text{EFLH} = \text{operating hours/day} * \text{operating days/yr}$
  - Enter this value as the **Power rating (W)** in WUFI
- Enter 1000 hrs/yr under 'Additional data'
  - Multiplied by 'Power rating (W)' entry to get total kWh/yr
- Example: A 1,500 sf office space open 8a-5p M-F has an EPD of 0.6 W/sf
  - $0.6 * 1500 * (9*250) / 1000 = 2025 \text{ W}$

## WUFI

Utilization pattern		Occupancy	Office equipment	Kitchen equipment	Lighting	Process loads	
Name	Type	Utilization pattern	Quantity [l]	Within thermal envelope	Power rating [W]	Power rating (saving mode) [W]	
All planned equipmer	User defined		1	<input checked="" type="checkbox"/>	2025		<input type="button" value="New"/> <input type="button" value="Delete"/> <input type="button" value="Copy"/> <input type="button" value="Insert"/> New/Insert: after

Additional data: All planned equipment

Utilization hours per year [hrs/yr]	1000
-------------------------------------	------

## METr

Occupancy		Office equipment	Kitchen equipment	Lighting	Process loads		
Nr	Name	Type	Utilization pattern	Quantity	Within thermal envelope	Power rating [W]	Power rating (saving mode) [W]
1	All planned equipment	User defined		1	<input checked="" type="checkbox"/>	2025	

Additional data, equipment: 1

Utilization hours per year [hrs/yr]	1000
-------------------------------------	------



# Non-Res Office Equipment

- Granular Method

- Create a unique line item for each piece of electrical equipment in the building & set the appropriate device type: PC/Monitor, copier, printer, server, telephone system, or 'user-defined'
  - Refer to Appendix I-3.11 (GB 2024) for typical non-residential equipment power consumption
  - Consolidate like-equipment as much as possible
  - Calculate inputs for user-defined equipment as described in the previous slide
- Some predefined equipment types require an entry for the power rating in 'sleep' or 'power saving' mode
  - Time in power saving mode is automatically calculated. Don't input anything when prompted

## WUFI

Utilization pattern	Occupancy	Office equipment	Kitchen equipment	Lighting	Process loads				
Name	Type	Utilization pattern	Quantity []	Within thermal envelope	Power rating [W]	Power rating (saving mode [W])			
PC - 1FL	PC	Pattern 2: Office - 1st	55	<input checked="" type="checkbox"/>	83	4			
PC - 2-5 FL	PC	Pattern 3: Office - 2-5f	230	<input checked="" type="checkbox"/>	83	4			
Copier - 1FL	Copier	Pattern 2: Office - 1st	7	<input checked="" type="checkbox"/>	400	30			
Copier - 2-5 FL	Copier	Pattern 3: Office - 2-5f	20	<input checked="" type="checkbox"/>	400	30			
Printer-Lable - 1FL	Printer	Pattern 2: Office - 1st	20	<input checked="" type="checkbox"/>	50	2			
Printer Lable - 2-5FL	Printer	Pattern 3: Office - 2-5f	59	<input checked="" type="checkbox"/>	50	2			
Printer OMR - 1FL	Printer	Pattern 2: Office - 1st	26	<input checked="" type="checkbox"/>	300	2			

## METR

Occupancy	Office equipment	Kitchen equipment	Lighting	Process loads					
Nr	Name	Type	Utilization pattern	Quantity	Within thermal envelope	Power rating [W]	Power rating saving mode [W]		
1	PC - 1FL	PC	Pattern 2: Office - 1st FL	55	<input checked="" type="checkbox"/>	83	4		
2	PC - 2-5 FL	PC	Pattern 3: Office - 2-5th FL	230	<input checked="" type="checkbox"/>	83	4		
3	Copier - 1FL	Copier	Pattern 2: Office - 1st FL	7	<input checked="" type="checkbox"/>	400	30		
4	Copier - 2-5 FL	Copier	Pattern 3: Office - 2-5th FL	20	<input checked="" type="checkbox"/>	400	30		



# Non-Res Office Equipment

## WUFI

Name	Type	Utilization pattern	Quantity [-]	Within thermal envelope	Power rating [W]	Power rating (saving mode) [W]
PC - 1FL	PC	Pattern 2: Office - 1st	55	<input checked="" type="checkbox"/>	83	4
PC - 2-5 FL	PC	Pattern 3: Office - 2-5th	230	<input checked="" type="checkbox"/>	83	4
Copier - 1FL	Copier	Pattern 2: Office - 1st	7	<input checked="" type="checkbox"/>	400	30
Copier - 2-5 FL	Copier	Pattern 3: Office - 2-5th	20	<input checked="" type="checkbox"/>	400	30
Printer-Lable - 1FL	Printer	Pattern 2: Office - 1st	20	<input checked="" type="checkbox"/>	50	2
Printer Lable - 2-5FL	Printer	Pattern 3: Office - 2-5th	59	<input checked="" type="checkbox"/>	50	2
Printer OMR - 1FL	Printer	Pattern 2: Office - 1st	26	<input checked="" type="checkbox"/>	300	2

Additional data: Copier - 1FL  
Duration of utilization time in energy saving mode

\*-Optional data

## METr

Nr	Name	Type	Utilization pattern	Quantity	Within thermal envelope	Power rating [W]	Power rating saving mode [W]
1	PC - 1FL	PC	Pattern 2: Office - 1st FL	55	<input checked="" type="checkbox"/>	83	4
2	PC - 2-5 FL	PC	Pattern 3: Office - 2-5th FL	230	<input checked="" type="checkbox"/>	83	4
3	Copier - 1FL	Copier	Pattern 2: Office - 1st FL	7	<input checked="" type="checkbox"/>	400	30
4	Copier - 2-5 FL	Copier	Pattern 3: Office - 2-5th FL	20	<input checked="" type="checkbox"/>	400	30
5	Printer-Lable - 1FL	Printer	Pattern 2: Office - 1st FL	20	<input checked="" type="checkbox"/>	50	2

Additional data, equipment: 3  
Duration of utilization in energy saving mode\* [hrs/yr]

Leave blank for pre-defined devices. Only modify for user-defined



# Non-Res Kitchen Equipment

## • Simple Method

- Create one line-item in WUFI with type set to 'User defined'
  - Calculate/estimate annual kWh/yr of all planned kitchen equipment
    - $\text{kWh/yr} = \text{EPD} * \text{iCFA} * \text{EFLH} / 1000$
    - $\text{EFLH} = \text{operating hours/day} * \text{operating days/yr}$
  - Use this value as the kWh/d input in WUFI
  - Enter 1 utilization day/yr
- 
- Example: A 200 sf kitchen has an EPD of 1.2 W/sf and operates within a generic office (M-F, 8a-5p)
    - $1.2 * 200 * (9*250) / 1000 = \mathbf{540 \text{ kWh/yr}}$

## WUFI

Utilization pattern | Occupancy | Office equipment | **Kitchen equipment** | Lighting | Process loads

Marginal performance ratio DHW [-] (optional)

Name	Type	Utilization pattern	Quantity [-]	Within thermal envelope
Kitchen EPD 1.2 W/sf	User defined	Pattern 1: Classroom	1	<input checked="" type="checkbox"/>

Additional data: Kitchen EPD 1.2 W/sf

Norm demand [kWh/d]	540
Utilization days per year [days/yr]	1

## METr

Occupancy | Office equipment | **Kitchen equipment** | Lighting | Process loads

Marginal performance ratio DHW [-]

Nr	Name	Type	Utilization pattern	Quantity	Within thermal envelope
1	Kitchen EPD	User defined	Pattern 1: Classroom	1	<input checked="" type="checkbox"/>

Additional data, equipment: 1

Norm demand	[kWh/d]	540
Utilization days per year	[days/yr]	1



# Non-Res Kitchen Equipment

- Granular Method
  - Create a unique line item for each piece of electrical kitchen equipment in the building (cooktop, dishwasher, refrigerator, or user-defined)
    - Consolidate equipment as much as possible
    - If multiple 'cooking' appliances (microwaves, range, etc) or dishwashers are present, only enter them ONE time with a quantity of ONE
      - Enter the number of meals per utilization day. Assume **one meal per occupant** as the conservative approach for most projects
  - Calculate inputs for user-defined equipment as described in the previous slide

## WUFI

Utilization pattern | Occupancy | Office equipment | Kitchen equipment | Lighting | Process loads

Marginal performance ratio DHW [-] (optional)

Name	Type	Utilization pattern	Quantity [-]	Within thermal envelope	
Coffee Grinder	User defined	Pattern 3: Rm 105 - K 1		<input checked="" type="checkbox"/>	New
Microwave	Cooktop	Pattern 3: Rm 105 - K 1		<input checked="" type="checkbox"/>	Delete
Coffee maker	User defined	Pattern 3: Rm 105 - K 1		<input checked="" type="checkbox"/>	Copy
Tea Kettle	User defined	Pattern 3: Rm 105 - K 1		<input checked="" type="checkbox"/>	Insert
Fridge	Refrigerator		2	<input checked="" type="checkbox"/>	New/Insert after
Dishwasher	Dishwasher	Pattern 3: Rm 105 - K 1		<input checked="" type="checkbox"/>	

Additional data: Coffee Grinder

Norm demand [kWh/d]	0.1
Utilization days per year [days/yr]	254

## METr

Occupancy | Office equipment | Kitchen equipment | Lighting | Process loads

Marginal performance ratio DHW [-]

Nr	Name	Type	Utilization pattern	Quantity	Within thermal envelope	
1	Coffee Grinder	User defined	Pattern 3: Rm 105 - Kitchenette	1	<input checked="" type="checkbox"/>	
2	Microwave	Cooktop	Pattern 3: Rm 105 - Kitchenette	1	<input checked="" type="checkbox"/>	
3	Coffee maker	User defined	Pattern 3: Rm 105 - Kitchenette	1	<input checked="" type="checkbox"/>	
4	Tea Kettle	User defined	Pattern 3: Rm 105 - Kitchenette	1	<input checked="" type="checkbox"/>	
5	Fridge	Refrigerator	Pattern 3: Rm 105 - Kitchenette	2	<input checked="" type="checkbox"/>	
6	Dishwasher	Dishwasher	Pattern 3: Rm 105 - Kitchenette	1	<input checked="" type="checkbox"/>	

Additional data, equipment: 1

Norm demand [kWh/d]	0.1
Utilization days per year [days/yr]	254



# Non-Res Kitchen Equipment

- Occupancy-based equipment vs quantity-based equipment
  - Similar to residential projects, the use of appliances like cooktops, microwaves, coffee makers, dishwashers, and other devices that need to be manually turned on by an occupant to function is occupancy based.
    - Generally these should be input as if there is only ONE device
  - Appliances like refrigerators that are **constantly** running are not dependent on occupant use.
    - Therefore, the quantity of this kind of equipment should reflect the physical quantity of devices in the project

Utilization pattern | Occupancy | Office equipment | Kitchen equipment | Lighting | Process loads

Marginal performance ratio DHW [-]  (optional)

Name	Type	Utilization pattern	Quantity [-]	Within thermal envelope	
Coffee Grinder	User defined	Pattern 3: Rm 105 - K 1		<input checked="" type="checkbox"/>	New
Microwave	Cooktop	Pattern 3: Rm 105 - K 1		<input checked="" type="checkbox"/>	Delete
Coffee maker	User defined	Pattern 3: Rm 105 - K 1		<input checked="" type="checkbox"/>	Copy
Tea Kettle	User defined	Pattern 3: Rm 105 - K 1		<input checked="" type="checkbox"/>	Insert
Fridge	Refrigerator		2	<input checked="" type="checkbox"/>	New/Insert after
Dishwasher	Dishwasher	Pattern 3: Rm 105 - K 1		<input checked="" type="checkbox"/>	

Additional data: Microwave

Cooking  Cooking with electricity

Number of meals per utilization day [-]

Occupancy | Office equipment | Kitchen equipment | Lighting | Process loads

Marginal performance ratio DHW [-]

Nr	Name	Type	Utilization pattern	Quantity	Within thermal envelope	
1	Coffee Grinder	User defined	Pattern 3: Rm 105 - Kitchenette	1	<input checked="" type="checkbox"/>	+
2	Microwave	Cooktop	Pattern 3: Rm 105 - Kitchenette	1	<input checked="" type="checkbox"/>	+
3	Coffee maker	User defined	Pattern 3: Rm 105 - Kitchenette	1	<input checked="" type="checkbox"/>	
4	Tea Kettle	User defined	Pattern 3: Rm 105 - Kitchenette	1	<input checked="" type="checkbox"/>	
5	Fridge	Refrigerator	Pattern 3: Rm 105 - Kitchenette	2	<input checked="" type="checkbox"/>	
6	Dishwasher	Dishwasher	Pattern 3: Rm 105 - Kitchenette	1	<input checked="" type="checkbox"/>	-

Additional data, equipment: 5

Norm demand [kWh/d]



## Office/Kitchen Equipment - Supporting Documentation

- Must be able to confirm **all** associated modeling inputs
  - Device power rating and/or calculations showing how device energy consumption was determined
    - Comprehensive list of equipment
    - Datasheets
  - Quantities of devices/equipment
    - Takeoffs
  - Calculations/documentation to justify estimated runtime for user-defined devices



# Unfinished (“UF”) Equipment & Lighting

SKIP Office & Kitchen Equipment, Lighting & Process Loads. UF Projects should have **no** inputs in any of these sections.

**Move on to Rooms/Ventilation**



# Non-Res Lighting

## WUFI & Daylighting

- The built-in daylighting function in WUFI should NOT be used
  - Up to a 10% reduction in lighting power density may be used in situations where rooms have windows, and a daylighting control system, whether continuous or stepped control is used.
  - Project teams may take a greater reduction of lighting power where a comparative daylighting simulation is provided showing the percentage reduction of lighting energy over a baseline with no controls.

These are for the daylighting calculation. They should be kept at default values shown on the next slide

Name	Utilization pattern	Fraction of conditioned floor area [%]	Derivation from north [°]	Glazing Visible Transmittance	Room depth [m]	Room width [m]	Room height [m]
Workstations 1 - 103	Pattern 2: Rm 103 - W	0.16	0	Triple low-e glazing: 0.69	10	10	10
Waiting Room - 104	Pattern 4: Rm 104 - W	0.03	180	Triple low-e glazing: 0.69	10	10	10
Conference 101	Pattern 1: Rm 101 - C	0.09	90	Triple low-e glazing: 0.69	10	10	10
Workstations 2 - 111	Pattern 7: Rm 111 - W	0.08	90	Triple low-e glazing: 0.69	10	10	10
Private Office - 112	Pattern 8: Rm 112 - P	0.08	0	Triple low-e glazing: 0.69	10	10	10
Office - 121	Pattern 9: Rm 121 - O	0.16	180	Triple low-e glazing: 0.69	10	10	10
Work Room - 107	Pattern 5: Rm 107 - W	0.04	0	Triple low-e glazing: 0.69	10	10	10

Additional data: Workstations 1 - 103	
Facade has windows	<input type="checkbox"/>
Lintel height [m]	1
Window width [m]	1
Lighting control	Manually
Motion detector	<input type="checkbox"/>
Installed lighting power [W/m²]	1.47
Lighting full load hours [hrs/yr]	



# Non-Res Lighting

- Inputs for all of the following should not be changed from the default values:
  - Derivation from North: 0**
  - Glazing visible transmittance:**  
Double **low-e glazing: 0.78**
  - Room Depth/Width/Height: 10 ft**
  - Facade has windows: DO NOT check**
  - Lintel height/window width: 1 ft**
  - Lighting control: Manually**

## WUFI

Derivation from north [°]	Glazing Visible Transmittance	Room depth [ft]	Room width [ft]	Room height [ft]
0	Double low-e glazing: 0.78	10	10	10

Additional data: Library Open Stack

Facade has windows	<input type="checkbox"/>
Lintel height [ft]	1
Window width [ft]	1
Lighting control	Manually
Motion detector	<input type="checkbox"/>
Installed lighting power [W/ft²]	
Lighting full load hours [hrs/yr]	

## METr

Derivation from north [°]	Glazing visible transmittance [-]	Room depth [ft]	Room width [ft]	Room height [ft]
0	Double low-e glazing: 0.78	10	10	10

Additional data, lighting: 1

Facade has windows	<input type="checkbox"/>
Lintel height [ft]	1
Window width [ft]	1
Lighting control	Manually
Motion detector	<input type="checkbox"/>
Installed lighting power* [W/ft²]	
Lighting full load hours* [hrs/yr]	



# Non-Res Lighting

## • Simple Method

- Create one line-item in WUFI to account for the lighting power for the full building/space being modeled.
- Fraction of conditioned floor area
  - Input 1 to represent 100% of the floor area
- Calculate/estimate whole-building LPD (W/sf) and input in WUFI
  - Apply 10% daylighting reduction by multiplying LPD \* 0.9
- Calculate full load hours for lighting
  - EFLH = operating hours/day \* operating days/yr

## WUFI

Utilization pattern	Occupancy	Office equipment	Kitchen equipment	Lighting	Process loads				
Name	Utilization pattern	Fraction of conditioned floor area [-]	Derivation from north [°]	Glazing Visible Transmittance	Room depth [m]	Room width [m]	Room height [m]		
Whole Building LPD	Pattern 1: Classroom 1	0		Double low-e glazing: 0.78	10	10	10		

Additional data: Whole Building LPD

Facade has windows	<input checked="" type="checkbox"/>
Lintel height [m]	1
Window width [m]	1
Lighting control	Manually
Motion detector	<input type="checkbox"/>
Installed lighting power [W/m²]	0.17
Lighting full load hours [hrs/yr]	8760

## METr

Occupancy	Office equipment	Kitchen equipment	Lighting	Process loads					
Nr	Name	Utilization pattern	Fraction of conditioned floor area [-]	Derivation from north [°]	Glazing visible transmittance [-]	Room depth [m]	Room width [m]	Room height [m]	
1	Whole Building L	Pattern 1: Classroom	1	0	Double low-e glazing: 0.78	10	10	10	

Additional data, lighting: 1

Facade has windows	<input checked="" type="checkbox"/>
Lintel height [m]	1
Window width [m]	1
Lighting control	Manually
Motion detector	<input type="checkbox"/>
Installed lighting power* [W/m²]	0.17
Lighting full load hours* [hrs/yr]	8760



# Non-Res Lighting

## • Granular Method

- Same as above, but one line-item for each unique space
- Consolidate as much as possible
  - Appropriate to group rooms if they share a utilization pattern and have similar LPDs
- Fraction of conditioned floor area
  - Input % of total iCFA made up by each space
- Calculate/estimate LPD (W/sf) by space type and input in WUFI
  - Apply 10% daylighting reduction to applicable rooms only by multiplying LPD \* 0.9
- Do NOT input lighting full load hours

## WUFI

Utilization pattern	Occupancy	Office equipment	Kitchen equipment	Lighting	Process loads					
Name	Utilization pattern	Fraction of conditioned floor area [ ]	Derivation from north [ ]	Glazing Visible Transmittance	Room depth [m]	Room width [m]	Room height [m]			
Classrooms	Pattern 1: Classroom	0.311	0	Double low-e glazing: 0.78	10	10	10		New	
Community	Pattern 1: Classroom	0.062	0	Double low-e glazing: 0.78	10	10	10		Delete	
Gym	Pattern 1: Classroom	0.054	0	Double low-e glazing: 0.78	10	10	10		Copy	
Kitchen	Pattern 1: Classroom	0.029	0	Double low-e glazing: 0.78	10	10	10		Insert	
Circulation	Pattern 1: Classroom	0.479	0	Double low-e glazing: 0.78	10	10	10		New/insert after	

Additional data: Classrooms

Facade has windows	<input type="checkbox"/>
Lintel height [m]	10
Window width [m]	10
Lighting control	Manually
Motion detector	<input type="checkbox"/>
Installed lighting power [W/m²]	0.64
Lighting full load hours [hrs/yr]	

## METr

Occupancy	Office equipment	Kitchen equipment	Lighting	Process loads						
(No)	Utilization pattern	Fraction of conditioned floor area [ ]	Derivation from north [ ]	Glazing visible transmittance [ ]	Room depth [m]	Room width [m]	Room height [m]			
1	Pattern 1: Classroom	0.311	0	Double low-e glazing: 0.78	10	10	10			
2	Pattern 1: Classroom	0.062	0	Double low-e glazing: 0.78	10	10	10			
3	Pattern 1: Classroom	0.054	0	Double low-e glazing: 0.78	10	10	10			
4	Pattern 1: Classroom	0.029	0	Double low-e glazing: 0.78	10	10	10			
5	Pattern 1: Classroom	0.479	0	Double low-e glazing: 0.78	10	10	10			

Additional data, lighting: 1

Facade has windows	<input type="checkbox"/>
Lintel height [m]	10
Window width [m]	10
Lighting control	Manually
Motion detector	<input type="checkbox"/>
Installed lighting power*	[W/m²] 0.64
Lighting full load hours*	[hrs/yr]



# Lighting - Supporting Documentation

- Must be able to confirm **all** associated modeling inputs
  - Lighting plans & LPD Calculations
    - Fixture wattages
    - Fixture quantities
  - Fraction of conditioned floor area calculations
    - Granular modeling method for lighting only



# Non-Res Process Loads

- What is a process load?
  - “Energy consumed in support of a manufacturing, industrial, or commercial process other than conditioning spaces and maintaining comfort & amenities for the occupants of a building”
- Allowances apply to source energy limit, **not** space conditioning targets
  - Custom space conditioning targets may be permitted on a case-by-case basis
  - Office & retail spaces do not qualify for this allowance





# Non-Res Process Loads

- YES Process Loads

- Grocery store refrigeration
- Kiln in a pottery studio
- Tank water pumps in an aquarium
- Saws & dust collectors in a carpentry shop or makerspace
- Incubators/lab equipment in a hospital
- Fitness equipment in a gym

- NOT Process Loads

- Computers/monitors
- Staff lounge appliances
- Televisions
- Copiers/Printers (except in a building that is specifically a print-shop)
- Miscellaneous “amenity” equipment



# Non-Res Process Loads

- **Simple Method**
  - Create one line-item in WUFI to account for all process loads in the project
  - Calculate/estimate energy consumption (kWh/yr)
- **Granular Method**
  - Same as above, but one line-item for each unique space
    - Click into 'Total energy use' cell and use the [...] to input Power rating (W) & annual use hours
  - Consolidate similar equipment as much as possible
- Check the boxes for 'Include in Site & Source Energy Totals' and 'Increase source energy allowance' for all approved process-load devices

## WUFI

Utilization pattern		Occupancy	Office equipment	Kitchen equipment	Lighting	Process loads	
Name	Quantity [t]			Total energy use [kWh/yr]	Include in Site & Source Energy Totals	Increase source energy allowance	Inside thermal envelope
Kiln	1			5200	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

New  
Delete  
Copy  
Insert  
New/Insert:  
after

## METr

Occupancy		Office equipment	Kitchen equipment	Lighting	Process loads		
Nr	Name	Quantity	Total energy use [kBtu/yr]	Include in site & source energy totals	Increase source energy allowance	Within thermal envelope	
1	Kiln	1	5200	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	

Additional data, process: 1  
Comment comment

# Non-Res Modeling: Mechanical Ventilation

2024 Guidebook Section 1.4.4.10



# Ventilation

## General Considerations

- Controls may be more complicated
- Ventilation when vacant
  - Less infiltration than code
  - Ramp up period before occupancy?
- IMC / ASHRAE 62.1 controls required rates
- Can have process ventilation

Utilization pattern | Rooms ventilation | Summer ventilation | Exhaust ventilation

Name	Operating days per week [d/week]	Operating weeks per year [week/a]	
Ventilation	7	52	<a href="#">New</a> <a href="#">Delete</a> <a href="#">Copy</a> <a href="#">Insert</a> New/Insert: after <input type="text"/>

**Intermediate results**

Supply air due to persons [cfm]	26604
Total extract air demand [cfm]	20916
Design air flow rate [cfm]	20916
Average air flow rate [cfm]	7843.52
Average air change rate [1/hr]	0.64

**Additional data: Ventilation**

Setting	Daily operation schedule [h]	Fraction of design air flow [-]
Maximum	2	1
Standard	4	0.75
Basic	8	0.5
Minimum	10	0

**Pattern: Ventilation is used in:**

- Case 1, Zone 1, Ventilation/Rooms, Rooms ventilation
- Case 2, Zone 1, Ventilation/Rooms, Rooms ventilation (current zone)



# Ventilation

- Need to understand sequence of operations (SOO)
- Can be written in a few formats
- Should be converted to a few different flow conditions to be put into utilization patterns

## AIR HANDLING UNITS

A DDC CONTROLLER USING ELECTRIC ACTUATION CONTROLS THE ROOFTOP AIR HANDLING UNIT OPERATION AS FOLLOWS:

RUN CONDITIONS - SCHEDULED:

THE RTU SHALL RUN BASED UPON AN OPERATOR-ADJUSTABLE SCHEDULE.

### WARM-UP:

THE TERMINAL HEATING UNITS (RADIANT PANELS, WALL RADIATION UNITS, FIN/TUBE, ETC) VALVES SHALL MODULATE OPEN TO RAISE THE SPACES TO THE OCCUPIED SET POINT OF 70°F (ADJ.). ALONG WITH THE TERMINAL HEATING UNITS, THE RTU SHALL ALSO BE ACTIVATED. THE RTU OUTSIDE AND EXHAUST AIR DAMPERS SHALL BE CLOSED, THE RECIRCULATION DAMPER SHALL BE OPEN. THE TOTAL ENERGY RECOVERY WHEEL SHALL BE DE-ENERGIZED & ASSOCIATED ERW BYPASS DAMPERS SHALL CLOSE. THE SUPPLY FAN & RETURN FAN SHALL START AND RECIRCULATE BUILDING AIR. THE RTU HYDRONIC HEAT PUMP SHALL ENABLE IN HEATING MODE AND OPERATE TO MAINTAIN THE UNIT DISCHARGE AIR SETPOINT DURING WARM-UP OF 85°F (ADJ.). ONCE THE SPACE HAS REACHED SPACE SETPOINT, THE TERMINAL HEATING UNITS SHALL ENTER THE OCCUPIED MODE, ALLOWING THEIR HOT WATER VALVES TO MODULATE AS REQUIRED TO MAINTAIN THE SPACE SETPOINT. THE RTU SHALL ALSO ENTER OCCUPIED MODE. THE SYSTEM SHALL BE PREVENTED FROM ENTERING THE WARM-UP MODE MORE THAN ONCE PER DAY, THROUGH THE OPTIMIZED START PROGRAM LOGIC WITHIN THE DDC SYSTEM SOFTWARE. THE BMS SHALL MONITOR THE RATE OF TEMPERATURE RISE TO DETERMINE WHEN TO ACTIVATE THE WARM UP MODE TO ENSURE THAT THE BUILDING HAS REACHED ITS SETPOINT FOR OCCUPIED MODE.

### COOL-DOWN:

THE RTU OUTSIDE AND EXHAUST AIR DAMPERS SHALL BE CLOSED, THE RECIRCULATION DAMPER SHALL BE OPEN. THE TOTAL ENERGY RECOVERY WHEEL SHALL BE DE-ENERGIZED & ASSOCIATED ERW BYPASS DAMPERS SHALL CLOSE. THE RETURN FAN & SUPPLY FAN SHALL START AND RECIRCULATE BUILDING AIR. THE HYDRONIC HEATPUMP SHALL ENABLE IN COOLING MODE AND OPERATE TO MAINTAIN THE UNIT DISCHARGE AIR SETPOINT DURING COOL-DOWN OF 55°F (ADJ.). ONCE THE SPACE HAS REACHED SPACE SETPOINT OF 75°F (ADJ.), THE RTU SHALL ENTER OCCUPIED MODE. THE SYSTEM SHALL BE PREVENTED FROM ENTERING THE COOL-DOWN MODE MORE THAN ONCE PER DAY, THROUGH THE OPTIMIZED START PROGRAM LOGIC WITHIN THE DDC SYSTEM SOFTWARE. THE BMS SHALL MONITOR THE RATE OF TEMPERATURE DECREASE TO DETERMINE WHEN TO ACTIVATE THE COOL DOWN MODE TO ENSURE THAT THE SPACE HAS REACHED ITS SETPOINT FOR OCCUPIED MODE. ECONOMIZER MODE OF OPERATION SHALL OVERRIDE NORMAL COOL-DOWN MODE OF OPERATION DURING UNOCCUPIED MODE.

### OCCUPIED MODE:

#### GENERAL:

THE FANS START OR CONTINUE TO RUN AND THE RTU IS CONTROLLED AS FOLLOWS:

THE EXHAUST AND OUTDOOR AIR DAMPERS SHALL OPEN TO MINIMUM POSITION AND THE RETURN AIR DAMPER SHALL OPEN TO MAXIMUM POSITION. THE ENERGY RECOVERY WHEEL SHALL BE ACTIVATED ERW BYPASS DAMPERS CLOSE AND OPERATE PER THE SEQUENCES BELOW. THE SUPPLY AND RETURN FANS SHALL BE ACTIVATED OR CONTINUE TO RUN AND THE SUPPLY FAN SHALL ADJUST ITS SPEED BASED ON THE SUPPLY DUCT MOUNTED STATIC PRESSURE SENSOR LOCATED 3/4 DOWN STREAM. THE SYSTEM'S ACTUAL STATIC PRESSURE SETPOINT WILL BE PROVIDED/OBTAINED THROUGH THE TESTING AND BALANCING CONTRACTOR DURING THE BALANCING PROCESS WITH THE HELP OF ATC CONTRACTOR. THE RETURN FAN SHALL TRACK THE SUPPLY FAN WITH A 5% (ADJ.) OFFSET TO MAINTAIN THE BUILDING AT A SLIGHTLY POSITIVE PRESSURE. THE ATC CONTRACTOR SHALL PROVIDE LOGIC TO CONSISTENTLY COLLECT THE TOTAL CFM FROM ALL VAV BOXES AND UTILIZE THAT VALUE IN CONJUNCTION WITH THE EXHAUST AIR FLOW SYSTEM CURVE PROFILE TO MODULATE THE RETURN FAN VFD. THE STATIC PRESSURE SET POINT SHALL BE RESET BASED ON PID (PROPORTIONAL-INTEGRAL- DERIVATIVE) LOGIC TO ALLOW THE VAV BOX ZONE REQUIRING THE MOST PRESSURE TO SATISFY ITS AIRFLOW REQUIREMENT AT ITS DESIGN FULL OPEN POSITION. THE STATIC PRESSURE SET POINT SHALL BE LOWERED TO THE POINT WHERE FAN SPEED REDUCTION CAN OCCUR, YET STILL ENSURE THAT THE VAV BOX ZONES REMAIN SATISFIED. THE SYSTEM SHALL USE INPUT SIGNALS FROM VAV BOX CONTROLLERS, THE MAIN DUCTWORK MOUNTED SYSTEM STATIC PRESSURE SENSOR AND THE CONTROLLER'S PROGRAM ALGORITHM TO ACHIEVE THIS CONTROL. IN ADDITION, PROVIDE DETECTION AND ALARM OF ANY VAV ZONE THAT EXCESSIVELY NEGATIVELY DRIVES THE RESET LOGIC. THE BMS SYSTEM SHALL BE CAPABLE OF ALLOWING OPERATOR TO READILY REMOVE OR ADD VAV BOX ZONES FROM THE RESET LOGIC ALGORITHM. THE PROJECT TAB/ATC CONTRACTORS SHALL FIELD DETERMINE THE ADJUSTABLE SETPOINT RANGE FOR EACH RTU/AHU SYSTEM AND THE PRIMARY VAV BOX UTILIZED TO CONTROL THE STATIC PRESSURE RESET CONTROL STRATEGY.



# Ventilation

- Can model by unit or by space
- By space allows understanding average flow rates
- Multipliers are your friend

Utilization pattern Rooms ventilation Summer ventilation Exhaust ventilation

Rooms

Name	Room type	Quantity	Utilization pattern	Design volume flow rate [cfm]		Average volume flow rate [cfm]		Average air change rate [1/hr]	
				Supply Air	Exhaust Air	Supply Air	Exhaust Air		
Classrooms	User defined	24	Pattern 1: Ventilation	450	450	168.8	168.8	10125	New
Cafe	User defined	1	Pattern 1: Ventilation	3500	3500	1312.5	1312.5	78750	Delete
Gym	Kitchen	1	Pattern 1: Ventilation	4000	4000	1500	1500	90000	
Offices	Kitchen	15	Pattern 1: Ventilation	100	100	37.5	37.5	2250	
				Σ 19800	19800	7425	7425	0.73	

Additional data: Offices

Design volume flow rate interzonal [cfm]	1
Area [ft²]	1
Clear room height [ft]	1


Standard dataset

Needed only to evaluate the average room air change rate. Not for further calculations



# Ventilation

- Commonplace in mechanical practice for combined conditioning in ventilation
- Not precluded
- Challenges in testing
  - Need to verify OA flow rate
  - Assume mixed air
  - Can calculate OA flow to space as % of total flow
  - Or run in ventilation only mode








# Demand Control Ventilation (DCV)

Many Non-residential buildings run a BAS

- Allows for detailed controls of mechanical systems
- DCV
  - Varies OA / EA rate based on pollutant concentration
  - CO<sub>2</sub>
  - VOC
  - CO

## Indoor environment: Simple mass balance



$$V \frac{dC}{dt} = PQC_{out} - QC + E$$



# Demand Control Ventilation Paths


## Path A: Engineers Model

- Utilize hourly flow rate from engineers model
- Bin flow rates for WUFI utilization pattern

## Path B: Iterative mass balance

- Utilize assumptions for exterior CO<sub>2</sub> and occupant generation rates
- Python / Excel
- Bin flow rated for WUFI

DCV in a School





# Demand Control Ventilation for WUFI

Bin Limits [m3/h]	Room_217	Room_215	Room_213	Room_211	Room_209
100	5366	5366	5783	5366	5366
400	1305	1305	888	1305	1305
800	1827	1827	1827	1827	1827
1200	0	0	104	0	0
Overflow (Count towards max flow rate)	261	261	157	261	261

Utilization pattern Rooms ventilation Summer ventilation Exhaust ventilation

Name	Operating days per week [d/week]	Operating weeks per year [week/a]	
Ventilation	7	52	

Intermediate results

Supply air due to persons [cfm]	26604
Total extract air demand [cfm]	20916
Design air flow rate [cfm]	20916
Average air flow rate [cfm]	10022.27
Average air change rate [1/hr]	0.82

Additional data ventilation

Setting	Daily operation schedule [h]	Fraction of design air flow [-]
Maximum	2	1
Standard	4	0.75
Basic	8	0.5
Minimum	10	0.25

Pattern: Ventilation is used in:

- Case 1, Zone 1, Ventilation/Rooms, Rooms ventilation
- Case 2, Zone 1, Ventilation/Rooms, Rooms ventilation (current zone)

# On-Site Review

2024 Guidebook Section 1.5



# Non-Residential On-Site Review

The intent of on-site review work is to confirm what was built on-site so the energy model can be updated to align. The general concept of Phius' on-site review requirements for non-residential projects follows the same logic as residential projects.

EPA Energy Star MFNC, IAP and DOE ZERH Checklists must be completed for all applicable items.

The checklists shall be applied to non-residential projects "as if" certification would be achieved, however, certification is not required.

# Mixed-Use On-Site Review

Phius Quality Control Checklist & Quality Assurance Workbook is required for all projects.

## Residential Portion

- Energy Star **Certification**
- Indoor AirPlus **Certification**
- Zero Energy Ready Home **Certification**
- Compartmentalization Testing
- Ventilation Testing & Balancing Report(s)
- Heating/Cooling Testing & Balancing Report(s)

## Non-Residential Portion

- Co-Requisite Program **Checklists**
  - Applicable Items Only
  - May vary by non-residential project scope and program
- Ventilation Testing & Balancing Report(s)
- Heating/Cooling Testing & Balancing Report(s)

# Future of Non-Residential Projects

2024 Guidebook Section 1.5

# Coming at some point...

## Short-Term

- Phius 2024 Non-Residential On-Site Quality Assurance Workbook
- More Supporting Calculators
  - Lighting
  - Mixed-Use Targets/Results
- METr Software Updates

## Long-Term

- Phius 2027
  - 227P ASHRAE



Thank you!

Questions?